NOTE:-

- UPVC SPACER REQUIRED WHERE DISSIMILAR METALS ARE BEING USED TO PREVENT GALVANIC CORROSION 1.
- FIRE HYDRANT RISER SQUARE MARGIN BLOCK TO BE A MINIMUM OF 450mm X 450mm X 450mm AS PER AS2419.1 2.
- MARGIN BLOCKS IN LANDSCAPED AREAS (UNGRASSED) TO BE 100MM ABOVE FINISHED GROUND LEVEL

TRACER WIRE CONNECTION TO ABOVE GROUND PIPEWORK			PROJECT: STANDARD DETAILS
Griffith UNIVERSITY	DATE 11/08/2021	DRAWN BY JS	HYDRAULIC SERVICES
Queensland, Australia PLANNING, DESIGN & CONSTRUCTION	SCALE NOT TO SCALE	APPROVED BY JA	PROJECT No: N/A
CORPORATE SERVICES 170 KESSELS ROAD, NATHAN, BRISBANE, QLD. 4111 PH:(07) 3735 7111 griffith.edu.au	DISCIPLINE HYDRAULIC	REVISION 2	DRAWING No: SHEET No: GSD-804 1 of 1