



NOTE:-

- INSTALL A MIN. 100MM OF BEDDING SAND UNDER BASE AND AROUND CRATES BETWEEN GEOTEXTILE LAYER AND EXISTING GROUND. ENSURE TRENCH WALLS ARE SCARIFIED BEFORE INSTALLATION OF MODULAR DRAINAGE CELLS
- WHERE WATER TABLE HIGHER THAN BASE OF ACCESS PIT DRAINAGE SEEK GRIFFITH UNIVERSITY APPROVAL
- RUBBLE FILLED TRENCHES TO BE A MIN. OF 3 TIMES THE CAPACITY OF DRAINAGE CELL (VOID) SIZES INDICATED
- DRAINAGE CELL SIZES SHOWN ARE INDICATIVE ONLY (AUSDRAIN)
- GRATED FLOOR DRAIN OUTLET TO BE POSITIONED CLEAR OF EQUIPMENT IN PIT FOR EASY ACCESS

TITLE  
PIT DRAINAGE - >900 SQ. PIT OR HV

PROJECT:  
STANDARD DETAILS  
HYDRAULIC SERVICES



PLANNING, DESIGN & CONSTRUCTION  
CORPORATE SERVICES

170 KESSELS ROAD, NATHAN, BRISBANE, QLD. 4111 PH:(07) 3735 7111 griffith.edu.au

DATE  
11/08/2021

DRAWN BY  
WO

SCALE  
1:40

APPROVED BY  
JA

DISCIPLINE  
HYDRAULIC

REVISION  
2

PROJECT No:  
N/A

DRAWING No:  
GSD-806C

SHEET No:  
1 of 1